

January 26, 2024

**POLK COUNTY, A POLITICAL SUBDIVISION OF
THE STATE OF FLORIDA**

**ADDENDUM #5
BID# 24-011**

Inwood Elementary School Project

This addendum is issued to clarify, add to, revise and/or delete items of the Contract Documents for this work. This Addendum is a part of the Contract Documents and acknowledgment of its receipt shall be noted below and on the Bid Submittal Form.

Contained within this addendum: Questions asked and answered.

Michael Guerrero

Michael Guerrero
Sr. Procurement Analyst
Procurement Division

**This Addendum sheet should be signed and submitted with
your bid submittal.**

Signature: _____

Printed Name: _____

Title: _____

Company: _____

BID 24-011
Inwood Elementary School Project
ADDENDUM #5

Question 1: I received Addendum # 3 and had a concern with Question # 3 I asked. I asked if this project is Davis Bacon or Davis Bacon related. The answer cannot be Yes. They are two different things it needs to be one or the other. The main reason I ask is if the project is Davis Bacon Related then we can work up the cost based on the wage sheet that was unloaded to the FTP site a few days ago. Example is a concrete finisher is paid per the sheet you sent to the FTP site of 15.44 per hour that would be no problem and we would use those work classes with that wage. Now if the job is Davis Bacon then all the wage classes for this job goes away and the minimum wage for any person even a general laborer is 17.20 per hour. Then if that is the case bids will be much higher to price up the labor portion of the job.

Answer: This project is federally funded and requires use of Davis Bacon Wage Rates per FHWA's Form 1273 which is included in the construction contract.

Question 2: The plans call for 3' chain link fence to be installed while both fencing bits items are for 5'. Please confirm what height of fencing is required.

Answer: There is no Type A Fencing (farm) or wooden fence on the project. The existing residential chain-link fencing is to be replaced in-kind (e.g., same type and height) as indicated in the plans. All the fence removal, relocation and replacement should be bid using bid item 550-10-110. **Bid item 550-10-410 will not be utilized. A revised Bid Sheet will not be issued. Do not enter a price for this bid item.**

Question 3: Per addendum #3 no wood fencing is to be removed or installed, please confirm that pay item 550-10-410 will not be utilized.

Answer: Correct, there will be no wood fencing installed.

Question 4: If pay item 550-10-410 is to be used, please clarify what it is to be used for.

Answer: N/A

Question 5: Per addendum #3 no details were provided for the required fencing. FDOT standard details for type A fence call for double strands of barbed wire at the top of the fence. Please clarify if this is required.

Answer: Fencing will be replaced in-kind (e.g., 4' chain link with 4' chain link), use bid item 550-10-110. No Type A farm fencing will be utilized.