

January 24, 2024

**POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA  
ADDENDUM # 1  
BID # 24-122, Saddle Creek Park ADA Parking Pads & Sidewalks**

This addendum is issued to clarify, add to, revise and/or delete items of the Bid Document for this work. This Addendum is a part of the Bid Document and acknowledgment of its receipt shall be noted on the Addendum.

---

**Contained within this addendum:** questions and answers

Respectfully,

*Brad Howard*

Senior Procurement Analyst  
Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal. This is the only acknowledgment required.

Signature

Printed Name:

Title:

Company:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## **Bid # 24-122, Saddle Creek Park ADA Parking Pads & Sidewalks Addendum # 1**

---

Q1: Is this project Davis Bacon or Davis Bacon-related?

A1: Yes, please see pages 17-23 of the bid document for all federal clauses.

Q2: Is the Contractor required to be FDOT pre-qualified since its federally funded?

A2: No.

Q3: Will this project require certified payrolls?

A3: Yes, please see the HUD Special conditions provided in the Bid Attachments packet for more information. You can find instructions on how to access the Bid Attachments package on page 1 of the bid document.

Q4: What is the total LF of 5' sidewalks on this project?

A4: The total linear foot measurement is 69 linear feet - 60' for the restroom and 3' for each pavilion.

Q5: Does the project require a bond?

A5: No.

Q6: What is required for pavement marking paint or thermoplastic?

A6: Thermoplastic is required for the asphalt at the south restroom and regular marking paint is required for the pavilions.