

March 15, 2024

POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA

ADDENDUM #2 BID# 24-231

LAKE VICTORIA OUTFALLS PROJECT-ARP

This addendum is issued to clarify, add to, revise and/or delete items of the Contract Documents for this work. This Addendum is a part of the Contract Documents and acknowledgment of its receipt shall be noted below and on the Bid Submittal Form.

Contained within this addendum:

1. Questions and answers received.
2. **Corrected FTP File name (Bid 24-231, Lake Victoria Outfalls Project - ARP.zip) and Revised Bid Sheet (Addendum 2 Bid Sheet).**
3. General Information: Bidders who wish to enter the Lake Victoria Subdivision will need to contact Alice Overstreet with the Lake Victoria HOA at 863-660-9864. Alice will provide you with an access code.
4. Bid due date extension.

The Bid Receiving Date has been extended one (1) week. The **revised** Bid Receiving Date is Wednesday, April 3, 2024.

To obtain a copy of the **Bid Package, Addendum 2 Bid Sheet, and Specifications** please go the following FTP site: <https://ftp3.polk-county.net>, you will be prompted for a User ID and Password. The User ID is procurevendor and the password is solicitation. After you have logged in to the FTP site, double click on the file folder "**Bid 24-231, Lake Victoria Outfalls Project - ARP.zip**", select "Open" or "Save As" to download the Bid Package, Addendum 2 Bid Sheet, and Specifications. If you need assistance accessing this website due to ADA or any other reason, please email Michael Guerrero at michaelguerrero@polk-county.net.

Michael Guerrero

Michael Guerrero
Sr. Procurement Analyst
Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal.

Signature: _____

Printed Name: _____

Title: _____

Company: _____

BID 24-231
LAKE VICTORIA OUTFALLS PROJECT-ARP
ADDENDUM #2

Question 1: On the plans (sheet 4), is manhole #2 located behind a wall?

Answer: Yes, down in the corner of the AVP property (inside the wall of the development).

Question 2: From grate #1, are you including that in the outfall? From the structure into the body of water.

Answer: Yes, that piece is included for lining.

Question 3: Is the County going to contact the homeowner near Scott Lake Baptist Church about access to the property?

Answer: Yes. There is a drainage easement, but the County will contact the homeowner.

Question 4: How will we get access for our boilers and other equipment as it relates to the church?

Answer: The County has a 15' Drainage Easement that covers a portion of Lake Cove Trail and reserves the right to utilize the entire easement to make the necessary repairs to the County's Drainage assets. The Contractor will be responsible for MOT for Lake Cove Trail which is a private road. The road must remain open for the duration of the Project.

Question 5: Are you going to want samples for this project? If so, what kind of samples?

Answer: Samples will not be required. The County only requests that the Contractor submit the engineering report for the lining material.

Question 6: Is it all 30" getting lined?

Answer: The pipe lining is a combination of 30" and 18" CMP. New construction is of only 30" diameter pipe.

Question 7: If the measurement of the thickness of the liners is different from what is on the bid sheet, how do we get paid?

Answer: The bid sheet has been revised to remove the thickness from the pay item description. See first page for instructions on accessing the revised bid sheet from the County's FTP Site.

Question 7: For the 18"---250ft line segment heading towards Highland lake; are you requiring lining to the catch basin or all the way to the outfall?

Answer: The lining will only go to the existing catch basin. A new pipe was installed a few years back between the existing catch basin and Highland Lake.

Question 8: Bid sheet in excel version has the 30" CIPP in SY unit of measure. Please revise to LF.

Answer: See first page for instructions on accessing the revised bid sheet from the County's FTP Site.