## POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA ADDENDUM # 1 BID 24-172, MOTOR CONTROL CENTERS (MCC-1 & MCC-2) EQUIPMENT AND SERVICES

This addendum is issued to clarify, add to, revise and/or delete items of the Bid Document for this work. This Addendum is a part of the Bid Document and acknowledgment of its receipt shall be noted on the Addendum.

Contained within this addendum: Revisions, Questions and Answers received.

To receive a copy of **Bid 24-172 Addendum 1 Revised Technical Specifications**, please go to the following FTP site: <a href="https://ftp3.polk-county.net">https://ftp3.polk-county.net</a>, you will be prompted for a User ID and Password. The User ID is *procurevendor* and the password is *solicitation*. After you have logged in to the FTP site, double click on the file folder "**Bid 24-172 Motor Control Centers Equipment and Services.zip**", select "Open" or "Save As" to download the revised technical specifications. If you need assistance accessing this website due to ADA or any other reason, please email Ari Goldstein at <a href="mailto:arigoldstein@polk-county.net">arigoldstein@polk-county.net</a>.

Ari Goldstein	
Ari	Goldstein

Senior Procurement Analyst Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal. This is the only acknowledgment required.

Signature	
Printed Name:	
Title:	
Company:	

## BID 24-172, MOTOR CONTROL CENTERS (MCC-1 & MCC-2) EQUIPMENT AND SERVICES

Addendum # 1

## **REVISIONS**

1: DELETE IN ITS ENTIRETY: Attachment "A" Technical Specifications

REPLACE WITH: Bid 24-172 Addendum 1 Revised Technical Specifications

**Note:** The change was adding Technical Specifications – Section 16443 Motor Control Center – Part 2 – Products, 2.1 Materials, A.15 – (pg 16443-5) and renumbering Items 15, 16, 17 to 16, 17, 18 in this section for the revised technical specifications.

## **QUESTIONS AND ANSWERS**

Question 1: Per sheet 44 of the bid package there are 395 days allowed for this contract. Per the electrical gear specifications all items are "Square-D, no equal". Will the County grant the awarded contractor contract time extensions if the County sole-sourced gear manufacturer cannot meet those days? None of the major gear suppliers are currently shipping items at the lead times provided during a bid period.

Answer 1: A time extension may be offered if necessary and the County PM will take it into consideration once the bid has been awarded.