

March 22, 2024

POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA

ADDENDUM # 1

CQ # 24-167, Sheriff Aviation Hangar – Roof Replacement

This addendum is issued to clarify, add to, revise and/or delete items of the Bid Document for this work. This Addendum is a part of the Bid Document and acknowledgment of its receipt shall be noted on the Addendum.

Contained within this addendum: Question & answer and revision.

Respectfully,

Tabatha Shirah

Tabatha Shirah
Procurement Analyst
Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal. This is the only acknowledgment required.

Signature

Printed Name:

Title:

Company:

CQ 24-167, Sheriff Aviation Hangar – Roof Replacement Addendum # 1

Question 1: When can we access the roof to take measurement?

Answer 1: Vendors must first check-in at the Sheriff Aviation Office (4898 Ben Durrance, Bartow, FL 33810). The facilities are accessible Monday – Friday between the hours of 8:00am-5:00pm.

Revision # 1

Delete in its entirety:

CQ 24-167 Drawings & Technical Specifications (FTP Site), Page 3, 1.1 SUMMARY:

1.1 SUMMARY

- A. Membrane Type: Duro-Tuff 50-Mil Membrane (Roll Goods)
 - 1. Roll Width: 60" (Installed widths may vary)
 - 2. Membrane Color: White
 - 3. Attachment Type: Mechanically Fastened
 - 4. Fasteners: Duro-Last® EHD Screw (#15)
 - 5. Plates: Duro-Last® Poly-Plate
- B. Insulation Layer 1 Type: Duro-Guard® ISO II (Glass Reinforced Facer)
 - 1. Board Application: Flat Stock
 - 2. Board Style: Layer Thickness
 - 3. Board Size: 4' x 8'
 - 4. Thickness: 3"
 - 5. Attachment Type: Mechanically Fastened
 - 6. Fasteners: Duro-Last® EHD Screw (#15)
 - 7. Plates: Duro-Last® Insulation Plate
- C. Insulation Layer 2 Type: Duro-Guard® EPS Type I, II, and VIII Flute Filler
 - 1. Board Application: Flat Stock
 - 2. Board Style: Layer Thickness
 - 3. Board Size: Custom
 - 4. Thickness: 1.25"
 - 5. Attachment Type: Loose-Laid
 - 6. Loose-Laid: Loose-Laid
- D. Deck Type: Standing Seam Metal Roof
- E. Prefabricated flashings, corners, parapets, stacks, vents, and related details.
- F. Fasteners, adhesives, and other accessories required for a complete roofing installation.
- G. Traffic Protection.

**CQ 24-167, Sheriff Aviation Hangar – Roof Replacement
Addendum # 1**

Replace with:

1.1 SUMMARY

- A. Membrane Type: Duro-Tuff 50-Mil Membrane (Roll Goods)
 - 1. Roll Width: 60" (Installed widths may vary)
 - 2. Membrane Color: White
 - 3. Attachment Type: Mechanically Fastened
 - 4. Fasteners: Duro-Last® EHD Screw (#15)
 - 5. Plates: Duro-Last® Poly-Plate
- B. Insulation Layer 1 Type: Duro-Guard® ISO II (Glass Reinforced Facer)
 - 1. Board Application: Flat Stock
 - 2. Board Style: Layer Thickness
 - 3. Board Size: 4' x 8'
 - 4. Thickness: 1.5"
 - 5. Attachment Type: Mechanically Fastened
 - 6. Fasteners: Duro-Last® EHD Screw (#15)
 - 7. Plates: Duro-Last® Insulation Plate
- C. Insulation Layer 2 Type: Duro-Guard® EPS Type I, II, and VIII Flute Filler
 - 1. Board Application: Flat Stock
 - 2. Board Style: Layer Thickness
 - 3. Board Size: Custom
 - 4. Thickness: 3"
 - 5. Attachment Type: Loose-Laid
 - 6. Loose-Laid: Loose-Laid
- D. Deck Type: Standing Seam Metal Roof
- E. Prefabricated flashings, corners, parapets, stacks, vents, and related details.
- F. Fasteners, adhesives, and other accessories required for a complete roofing installation.
- G. Traffic Protection.

Revision # 1