POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA

ADDENDUM #2

CQ # 24-186 SM, Fleet Office - Remodel Existing Bathrooms

This addendum is issued to clarify, add to, revise and/or delete items of the Bid Document for this work. This Addendum is a part of the Bid Document and acknowledgment of its receipt shall be noted on the Addendum.

| _ | | | | _ | _ | | | | |
|------------|--------|---------|------------|------------|------|--------|-----|----------|--|
| Contained | | 41-: | _ | O | ο. | | | | |
| i ontained | within | Thie an | iaenai im: | LILIAGIIAN | X. 5 | anewar | ana | rawiginn | |
| | | | | | | | | | |

Respectfully,

7abatha Shirah

Tabatha Shirah Procurement Analyst Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal. This is the only acknowledgment required.

| Signature | |
|---------------|--|
| Printed Name: | |
| Title: | |
| Company: | |

CQ # 24-186 SM, Fleet Office – Remodel Existing Bathrooms Addendum # 2

Q1: Provide a specification for the toilet partition materials. Is this a laminate?

A1: See Revision #1 below for response.

Revision #1

Bid Package, Scope of Work, Item 14 - page 32:

Delete in entirety:

Supply and install new stall partition for restroom according to the Drawings and Technical Specifications on FTP Site sheet 5.

Replace with:

Supply and install new stall partition for restroom according to the Drawings and Technical Specifications on FTP Site Sheet 5 - Partition Material: 1" solid Plastic HDPE Toilet partition floor mounted Including all required overhead bracing and accessories (color to be approved).