

June 27, 2024

# POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA

## ADDENDUM #1 BID# 24-516

### KING BLVD. DRAINAGE IMPROVEMENT PROJECT - ARP

This addendum is issued to clarify, add to, revise and/or delete items of the Contract Documents for this work. This Addendum is a part of the Contract Documents and acknowledgment of its receipt shall be noted below and on the Bid Submittal Form.

Contained within this addendum:

1. Question received and answered.

*Michael Guerrero*

Michael Guerrero  
Sr. Procurement Analyst  
Procurement Division

**This Addendum sheet should be signed and submitted with your bid submittal.**

Signature: \_\_\_\_\_

Printed Name: \_\_\_\_\_

Title: \_\_\_\_\_

Company: \_\_\_\_\_

**BID 24-516**  
**KING BLVD. DRAINAGE IMPROVEMENT PROJECT - ARP**  
**ADDENDUM #1**

Question 1: Will ADS be an acceptable substitute for RCP?

Answer: Due to the high-water table conditions, RCP is the only pipe material acceptable for the Project.

Question 2: What are the details of the dewatering requirements?

Answer: There are no specific dewatering criteria required, other than the statewide requirement that no discharge can exceed 29 nephelometric turbidity units (NTUs) above background. Methods to achieve and maintain this are left to contractor's means and methods.