

August 29, 2024

**POLK COUNTY, A POLITICAL SUBDIVISION OF
THE STATE OF FLORIDA**

**ADDENDUM # 2
BID # 24-594, Polk County Tourism Office Expansion**

This addendum is issued to clarify, add to, revise and/or delete items of the Bid Document for this work. This Addendum is a part of the Bid Document and acknowledgment of its receipt shall be noted on the Addendum.

Contained within this addendum: questions and answers.

FTP Site:

To obtain a copy of Addendum 2 attachments go the following FTP site: <https://ftp3.polk-county.net>, you will be prompted for a User ID and Password. The User ID is procurevendor and the password is solicitation. After you have logged in to the FTP site, double click on the file folder "**Bid 24-594, Bid Attachments**", select "Open" or "Save As" to download. If you need assistance accessing this website due to ADA or any other reason, please email Tabatha Shirah at tabathashirah@polk-county.net.

Respectfully,

Tabatha Shirah

Procurement Analyst
Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal. This is the only acknowledgment required.

Signature _____
Printed Name: _____
Title: _____
Company: _____

BID # 24-594, Polk County Tourism Office Expansion

Addendum # 2

Q1: Sheet A3.0 shows full thickness concrete topping slab at second floor renovation. Detail 7/S1.2 shows EPS foam and 1" gypcrete. Could you please confirm which should be included in bid?

A1: 1" gypcrete with EPS foam as per detail 7/S1.2

Specification 035400 CEMENTITIOUS UNDERLAYMENT is the technical specification for this system. It is part of the bidding documents.

Q2: Please provide the ceiling grid and ceiling tile specs for this project?

A2: Specification 095123 SUSPENDED ACOUSTICAL CEILINGS is part of the bid package in the specifications manual. Reflected Ceiling plan A8.0 is part of the bid package in the drawings package for the scopes of work.

(Existing drawings "Lake Myrtle Development Tourism & Sports Marketing Headquarters" show the existing ceiling grids for the floors on the sheets A111 and A-112.)