

August 23, 2024

**POLK COUNTY, A POLITICAL SUBDIVISION OF
THE STATE OF FLORIDA**

**ADDENDUM #1
BID# 24-614**

IMPERIAL LAKES BLVD DRAINAGE IMPROVEMENT PROJECT - ARP

This addendum is issued to clarify, add to, revise and/or delete items of the Contract Documents for this work. This Addendum is a part of the Contract Documents and acknowledgment of its receipt shall be noted below and on the Bid Submittal Form.

Contained within this addendum:

1. Questions received and answered.
2. Addition to the Supplementary Conditions

Michael Guerrero

Michael Guerrero
Sr. Procurement Analyst
Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal.

Signature: _____

Printed Name: _____

Title: _____

Company: _____

BID 24-614
IMPERIAL LAKES BLVD DRAINAGE IMPROVEMENT PROJECT - ARP
ADDENDUM #1

Question 1: Do we have to maintain 4 lanes of traffic, or can we go down to two lanes?

Answer: No, you do not have to maintain 4 lanes of traffic. However, the MOT must always provide for two-way traffic on ILB and provide access to the side streets of Belmont Park Lane, Country Club Lane, Par Place, and Ryan Road open. No full road closures will be permitted on Imperial Lakes Blvd. Road closure of Old Colony Road will be permitted.

Question 2: How many times the proposed storm-sewer crosses over the existing 24" sanitary sewer?

Answer: There are two locations, at STA 115+00 and STA 117+80 (Conflict Box).

Question 3: Is the manhole S-13A on the plans?

Answer: Yes, S-13A is shown on the plan view and in detail on Sheet No. 57.

Addition to the Supplementary Conditions

Excavated material from the pond site is to be taken to the Polk County North Central Landfill (NCLF). This is only for fill material excavated from the pond site. The Contractor will be responsible for disposal of any other trash/debris from the site. Tipping fees at the NCLF will be waived. The NCLF is located at 7425 De Castro Road, Winter Haven, FL 33880, approximately 15 miles from the Project site.