

November 4, 2025

POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA

ADDENDUM # 2
CQ #25-693, FLEET MANAGEMENT - SHOP 2 ROOF REPLACEMENT

This addendum is issued to clarify, add to, revise and/or delete items of the Bid Document for this work. This Addendum is a part of the Bid Document and acknowledgment of its receipt shall be noted on the Addendum.

Contained within this addendum: Questions and answers.

Respectfully,

Tabatha Shirah
Tabatha Shirah
Procurement Analyst
Procurement Division

This Addendum sheet should be signed and submitted with your bid submittal. This is the only acknowledgment required.

Signature	_____
Printed Name:	_____
Title:	_____
Company:	_____

CQ # 25-693, Fleet Management - Shop 2 Roof Replacement
Addendum # 2

- Q1:** In the Quote Package – Scope of Work, item #15 request Berridge products for gutter and downspouts. Is there a specific style the County wants as the existing gutters and downspouts are not Berridge?
- A1:** Vendors are to include pricing to remove and replace existing gutters with Berridge Manufacturing Company metal to match the new roof panel colors per the specified scope of work provided. Gutter size shall be 6” Ogee configuration with 4” square downspouts
- Q2:** In the Qualifications “Berridge Cee-Lock Double Lock Panel Standing Seam Metal Roof System” is called out, but in the Scope of Work “Berridge Double Lock Zeelock Panel” are called out. Please specify which panel?
- A2:** Berridge Double Lock Zeelock Panel as noted on Drawing Sheet No. 103.
- Q3:** Who is the contact for Berridge for Certification Letter?
- A3:** Bob Wilinski | Regional Sales Manager | Berridge Florida Sales Corp.
Ph: (813) 335-4505
Email: bwilinski@berridge.com